



worst channel which has the maximum power increasing rate in the power regions. Figure 2 shows the power distribution of the S13 channel during the transient. A 10 % uncertainty of the power increasing rate is considered to conserve the safety margin.




Figure 2. Channel & Reactor power transient

### 2.3 Thermal-hydraulics Results

The geometry of the S13 channel is generated from the CATGEN-6 code [5]. Modified S13 (S13\_mod) channel is modeled for CATHENA single channel analysis. Channel S13\_mod has the same geometry as S13 but the channel power and the bundle power of the two center bundles have been modified to the licensing limits of 7.3 MW and 935 kW, respectively. The S13 channel flow rate applies the design value of 26.62 kg/s.

Figure 2 shows the reactor power transient at 75%FP and 100%FP during the accident. The RRS compensates the positive reactivity added due to the dilution of the moderator poison concentration by the un-poisoned coolant being discharged and the increase of the moderator temperature during the early period. But the moderator purity is degraded due to the discharged coolant having a lower initial isotopic purity than the moderator, which introduces a negative reactivity. Also it is shown that the increase of the reactor power depends upon the moderator poison concentration. The reactor power is relatively stable and controllable within the RRS capacity during the transient. As shown in Figure 3, a fuel dryout does not occur at 10mk@100%FP and at 30mk@75%FP, but at 176.1 seconds at 15mk @100%FP.




Figure 3. Reactor power and fuel temperature transient

### 2.4 Moderator Analysis Results

The bulk moderator temperature is shown in Figure 4. Throughout the entire transient, no moderator bulk boiling is predicted. The bulk moderator temperature increases up to around 101 °C at 200 seconds. The bulk

moderator temperature increment is higher for the over-poisoned moderator case.




Figure 4. Bulk moderator temperature transient at 100%FP

### 2.5. Assessment Results

The effective trip parameters and trip times derived from the assessment of a PTR are shown in Table 1. The effective trip parameters are the low PHT pressure (LP) and the pressurizer low level (PLL) signals for both the SDS1 and SDS2 prior to an onset of a fuel dryout. As listed in Table 1, the results show the existence of enough margins to a fuel dryout at the second trip time for each shutdown system within the limited poison concentration of the moderator (30 mk at 75%FP and 10 mk at 100%FP).

Table 1. Effective trip parameters and trip times

Reactor Power	75%FP		100%FP	
Poison Concentration in Moderator (mk)	30	10	15	
SDS1 LP Trip (sec)	165.15	176.93	190.03	
SDS2 LP Trip (sec)	165.25	177.03	190.13	
SDS1 PLL Trip (sec)	165.35	184.93	194.03	
SDS2 PLL Trip (sec)	165.45	185.03	194.13	
Onset of Dryout Time (sec)	No Boiling	No Boiling	176.1	

### 3. Conclusion

With the working RRS, at least two trip parameters for each shutdown system are effective in preventing a fuel dryout. The reactor power stability is maintained in the event of a PTR while the moderator contains substantial amounts of neutron absorbing poisons. Significant margin to a dryout exist at the time of the second trip signal under the given moderator poison concentration.

### REFERENCE

- [1] KHNP, "Final Safety Reports for Wolsong NPPs 2, 3 & 4".
- [2] AECL, "CATHENA MOD-3.5: Theoretical Manual, COG-93-140", Rev 00, 1995.
- [3] AECL, "MODSTBOIL MOD-2.1: Manual and Program Description", TTR-560, 1995.
- [4] AECL, "RFSP Manual: User's Manual for Microcomputer Version", TTR-321, Rev.1/COG-93-104, July 1993.
- [5] AECL, "CATGEN-6 Users Manual", 86-03500-AR-014, July 1992.