

空氣 調和 熱負荷計算

李 鍵*

공기조화 열부하 계산방법으로는

① 概算負荷推定(略算) 面積當 냉동기 보일러의 크기 推定

② 장치설계를 위한 負荷計算 各 室別 負荷 계산 用紙에 의거 最大부하계산

③ 年間運轉費 推定을 위한 負荷計算의 종류가 있다.

현재 부하계산이라면 주고 2번을 칭한다. 이를 위한 설계 Data와 方法이 각종 문헌에 실려있다. 代表的인 것을 들면 다음 문헌들이 있다.


- 井上市市 空氣調和 Handbook(번역판있음)
- Carrier Handbook of A. C. System Design
- 건축설계자료집성 6권
- 日本 空氣調和 衛生工學會 編 便覽 第2권

○ Ashrae Handbook Fundamentals 1972 & 1977 (사진복사판있음)

이들 方法은 어느것이나 周期定常傳熱(Periodic steady heat transmission thru the wall) 계산법에 근거한 유효온도차 ETD(Equivalent Temperature Differential)의 表를 미리 계산하여 보여 주고 있다. 細部에 있어서는 약간식의 차이가 있다.

표 1에 냉방부하 계산항목과 항목별 계산식을 보여준다. 냉방부하 계산이 난방에 비하여 어렵고 복잡한 것은 주로 日射(Solar Radiation)의 영향이 커서 건물 外壁, 지붕과 유리창을 통한 열取得(Heat Gain)의 계산이 어렵기 때문이다.

이중 가장 어려운부분이 계산하고자 하는 벽체의 ETD 값을 表에서 찾아서 결정하는 일이다.



S: 현열취득(Sensible Heat Gain)
L: 잠열취득(Latent Heat Gain)

*正會員, 서울대학교 工科大學

各項目을 계산식은 아래와 같다.

1. $q_w = \text{열貫流率(Kor U값)} \times \text{有効溫度差(ETD)} \times \text{외벽면적}$
2. $q_{GS} = \text{일사열취득량}(I_{GS}) \times \text{차폐계수}(k_s) \times \text{유리면적}$
3. $q_{GT} = \text{유리면 열관류율}(K) \times \text{内外온도차}(\theta_0 - \theta_i) \times \text{유리면적}$
4. $q_{IFS} = 0.24 \times 1.2 \times \text{극간풍량}[m^3/Hr] \times \text{内外온도차}(\theta_0 - \theta_i)$
 $q_{IFL} = 720 \times \text{극간풍량}[m^3/Hr] \times \text{内外절대습도차}(x_0 - x_i)$
5. $q_L = \text{床面積} \times \text{面積當 watt 수} \times 1.0$ (형광등, 백열등은 0.86)
6. $q_{HS} = \text{床面積} \times \text{在室人口密度}[人/m^2] \times \text{人體의 방열량}$
 q_{HL}
8. $q_{VS} = 0.24 \times 1.2 \times \text{在室人수} \times 1인 당外氣量 \times \text{内外온도차}(\theta_0 - \theta_i)$
 $q_{VL} = 720 \times \text{在室人수} \times 1인 당外氣量 \times \text{内外절대습도차}(x_0 - x_i)$

표 1. 서울 및 동경의 하계외기조건 비교표

시각	서울 8月 외기조건					동경 하계 외기조건				
	DB°C	WB°C	RH%	절대습도	kg/kg	DB°C	WB°C	RH%	절대습도	kg/kg
1	25.3	24.5	94			26.9	25.2		0.0196	
2	25.2	24.5	94			26.6	25.2		0.0197	
3	25.1	24.5	95			26.3	25.0		0.0185	
4	25.0	24.5	95			26.2	24.7		0.0191	
5	24.9	24.5	96			26.1	24.8		0.0192	
6	24.8	24.2	97			26.4	24.8		0.0192	
7	25.0	24.3	95			27.8	25.3		0.0195	
8	25.9	24.5	90			29.3	25.8		0.0196	
9	27.3	25.0	83			30.9	26.3		0.0197	
10	28.8	25.3	76			31.9	26.7		0.0200	
11	30.4	25.0	70			32.5	26.8		0.0200	
12	31.8	25.8	64			32.8	27.0		0.0202	
13	32.7	26.2	61			33.2	27.0		0.0201	
14	33.2	26.2	59			33.2	27.0		0.0201	
15	33.1	26.2	60			33.5	27.1		0.0201	
16	32.1	26.2	63			32.8	26.9		0.0201	
17	30.9	26.0	68			31.8	26.7		0.0201	
18	29.6	26.0	73			30.7	26.4		0.0200	
19	28.3	25.3	79			29.4	26.0		0.0200	
20	27.3	25.2	83			28.7	25.9		0.0200	
21	26.3	24.6	88			28.1	25.6		0.0198	
22	25.7	24.6	92			27.8	25.7		0.0200	
23	25.5	24.6	93			27.5	25.4		0.0197	
24	25.4	24.6	93			27.1	25.3		0.0197	
평균	27.9°C	25.1°C	81%		0.0191	29.5°C	25.9°C	76%		0.0198

서울의 외기조건 :
 동경의 외기조건 : T. A. C. 2.5% 하계 온도조건

表 2. Air Conditioning Load Estimate

Project						197	. . . By			
Design condition						No.				
Out Side	°C DB	°C WB	%RH	°C DB	%RH					
Room	°C DB	°C WB	%RH	°C DB	%RH					
Space: Used For:										
Size:	×	=	M ² ×	=	M ^s					
ITEM	AREA		COOLING				HEATING			
	M×M	M ²	Kor S. F.	ΔTe or IG		kcal/hr		ΔT°C	FACTOR	kcal
				A. M.	P. M.	A. M.	P. M.			
ROOF										
FLOOR										
TRANSMISSION Σ										
SOLAR Σ								SUB-TOTAL		
PEOPLE		C×		kcal/hr, C				X/hr× m ³ =		
POWER		kW×		860				m ³ /hr		
LIGHT		W/m ²		m ² × 0.86				0.31× m ³ /hr×		
	1.2×	W/m ²		m ² × 0.86				INFILTRATION		
INTERNAL GAIN Σ							SAFETY FACTOR %			
INFILTRATION Σ	0.29×	X/hr×		m ³ × °C						
SUB TOTAL										
SAFETY FACTOR								%		
TOTAL SENSIBLE HEAT										
PEOPLE		C×		kcal/hr·c						
INFILTRATION	720×	X/hr×	M ³ ×	kg/kg						
SUB TOTAL										
SAFETY FACTOR										
TOTAL LATENT HEAT										
GRGRAND TOTAL COOLING & HEATING										
kcal/hr·m ²										




그림 1. 서울 및 동경의 夏季乾球 溫度比較




그림 2. 서울 및 동경의 夏季濕球 溫度比較




그림 3. 서울 및 동경의 하계 외기조건 비교




그림 4. 콘크리트 單層壁 貫流單位應答




그림 5. 壁體의 熱的分類 Type I~V (西面 ETD의 그림)

표 3. 壁體의 傳熱應答係數(三角 hold) 콘크리트 單層壁

L=5CM	D(1)	B(1)	C(1)
0	1.0000000	1.2131300	6.5079690
1	-0.4112006	1.5532210	-3.7272340
2	0.0000032	0.0279392	0.0135562
3	0.0000000	0.0000000	0.0000000
4	0.0000000	0.0000000	0.0000000
5	0.0000000	0.0000000	0.0000000
6	0.0000000	0.0000000	0.0000000
L=10CM	D(1)	B(1)	C(1)
0	1.0000000	0.2165003	6.5567470
1	-0.7035982	0.8938980	-5.5632090
2	0.0231846	0.1855831	0.3038927
3	-0.0000005	0.0008879	-0.0005022
4	0.0000000	0.0000000	0.0000000
5	0.0000000	-0.0000003	0.0000000
6	0.0000000	0.0000000	0.0000000
L=15CM	D(1)	B(1)	C(1)
0	1.0000000	0.0289364	6.5562580
1	-0.9788435	0.3349628	-7.3492560
2	0.1551044	0.2438922	1.4342280

空氣調和熱負荷計算

3	-0.0009899	0.0133956	-0.0200279
4	0.0000000	0.0000252	0.0000199
5	0.0000000	0.0000000	0.0000000
6	0.0000000	-0.0000003	0.0000000
L=20CM	D(1)	B(1)	C(1)
0	1.0000000	0.0034256	6.5563710
1	-1.2608320	0.0889339	-9.1976230
2	0.3725122	0.1689606	3.1265490
3	-0.0172220	0.0352259	-0.1891934
4	0.0000398	0.0007476	0.0011959
5	0.0000000	0.0000015	-0.0000014
6	0.0000000	0.0000002	-0.0000002
L=25CM	D(1)	B(1)	C(1)
0	1.0000000	-0.0011567	6.5555789
1	-1.5429260	0.0220690	-11.0451000
2	0.6683298	0.0746241	5.3272640
3	-0.0764282	0.0433181	-0.7131460
4	0.0013334	0.0033928	0.0177592
5	-0.0000016	0.0000351	-0.0000649
6	0.0000000	0.0000005	-0.0000006
L=30CM	D(1)	B(1)	C(1)
0	1.0000000	0.0014629	6.5548350
1	-1.8250200	-0.0010738	-12.3923000
2	1.0436290	0.0308962	8.0478930
3	-0.2023309	0.0294529	-1.748550
4	0.0103089	0.0071012	0.1075646
5	-0.0000842	0.0002442	-0.0013633
6	0.0000001	0.0000014	0.0000039

表 4.

Wall Composition		Shin Kkgusal BLD				
No	Material	Thickness L (centimeter)	Conductivity K (kcal/M-Hr-Deg)	Diffusivity A (Sq-Meter/Hr)	Resistance R (Sm-Hr-Deg/kcal)	Capacity C (kcal/Sm-Deg)
	Surface air Film		8.0000		0.1250	
1.	Mortar	2.50	1.2000	0.002000	0.0208	15.0000
2.	Concrete	15.00	1.4000	0.002500	0.1071	83.9999
3.	Mortar	3.00	1.2000	0.002000	0.0250	18.0000
4.	Tile	1.00	0.7600	0.001280	0.0132	5.9375
	Surface air film		20.0000		0.0500	
	Total	L=21.50	U=2.9314		R=0.3411	C=122.9374

Indicial Response

No.	Alpha	Heat Flux A		Surface Temperature	
		(Kanryu)	A (Kusyu)	A (Side-1)	A (Side-2)
		2.93140	2.93140	0.63358	0.14657
1.	0.14422	-4.19166	2.93858	-0.36732	-0.20958
2.	-0.85414	1.81901	0.93945	-0.11743	0.09095
3.	2.43306	-0.86152	0.38992	-0.04874	-0.04308
4.	4.93456	0.48910	0.20698	-0.02587	0.02445
5.	8.38236	-0.31090	0.12715	-0.01589	-0.01555
6.	12.81731	0.21481	0.08365	-0.01046	0.01074
7.	18.21780	-0.16023	0.05703	-0.00713	-0.00801
8.	24.50255	0.12566	0.04070	-0.00509	0.00628

Z-Transfer Function Coefficients (Triangle Hold)

No	D(1)	B(1)	C(1)
0	1.0000000	0.0025530	6.5139341
1	-1.3865347	0.0391417	-9.9633389
2	0.4920632	0.1220646	4.0122681
3	-0.0359209	0.0392297	-0.3626359
4	0.0002409	0.0017601	0.0045320
5	-0.0000001	0.0000064	-0.0000083
6	0.0000000	0.0000000	0.0000000

Z-Transfer Function Coefficients (Zeroth Hold)

No	D(1)	B(1)	C(1)
0	1.0000000	0.0000000	0.0000000
1	-1.3865347	0.0048046	5.9109230
2	0.4920632	0.1015558	-8.7997580
3	-0.0359209	0.0909653	3.3498087
4	0.0002409	0.0073859	-0.2580008
5	-0.0000001	0.0000401	0.0017828
6	0.0000000	0.0000008	-0.0000010

표 5. 손실열에 대한 Computer Program

Facom Bos/Vs Fostran S -770127- Vol-L14

Options in Effect (Fortsi)

Object, Nostack, Source, Nomap, Noisn, Ebcidc Noautodbl, Nosequence, Noasterisk,
Nodenseprint, Opt(O), Fmtarea(256), Flag(W), Debug(STD)

C	Heat Loss Calculation
0001	Dimension U(8), T(8), X(8)
0002	Dimension Cn(8), An(8)
0003	Dimension Xk(7)
0004	Read(5, 10) (U(N), N=1, 8)
0005	Read(5, 20) (T(N), X(N), N=1, 6)
0006	Read(5, 30) (Cn(N), An(N), N=1, 6)

空氣調和熱負荷計算

```

0007      Read(5, 40) (Xk(N), N=1, 5)
0008      Read(5, 40) Width, Xlgth, Xhgth, Adoor, Awidw
0009      Read(5, 50) Ewn, Swn, Wwn, Xwn
0010      Read(5, 50) Edn, Sdn, Wdn, Xdn
0011      Read(5, 60) Tp, Xp, Te
0012      10  Format(8F10, 5)
0013      20  Format(2F10, 5)
0014      30  Format(2F10, 5)
0015      40  Format(5F10, 5)
0016      50  Format(4F10, 5)
0017      60  Format(3F10, 5)
      C      Calculation of Room Capacity
0018      V=Width*XLgth*Xhgth
      C      Print of Title
0019      Write (6, 110)
0020      110 Format (/15X, 25H** Heat Loss Calculation**)
0021      Write (6, 120)
0022      Write (6, 130)
0023      120 Format (/6X, 4H Time, 7X, 8H Sensible, 7X, 8H Humidify, 6X, 10H Total
      Load)
0024      130 Format (17X, 8H (kcal/H), 9X, 6H(kg/H), 7X, 8H (kcal/H)
0025      Do 1000 I=1, 6
0026      Ewall=U(1)* (Width*Xhgth)-Ewn*Awidw-Edn*Adoor)*(Tp-T(I))* Xk (1)
0027      Swall=U(2)*((XLgth*Xhgth)-Swn*Awidw-Sdn*Adoor)*(Tp-T(I))* Xk (2)
0028      Wwall=U(3)* ((Width*Xhgth)-Wwn*Awidw-Wdn*Adoor)* (Tp-T(I))* Xk(3)
0029      Xwall=U(4)* ((XLgth*Xhgth)-Xwn*Awidw-Xdn*Adoor)* (Tp-T(I))* Xk(4)
0030      Roof=U(5) *Width*XLgth* (Tp-T(I))* Xk(5)
0031      Door=U(6) *Adoor* (Edn* Xk(1)+Sdn*Xk(2)+Wdn*Xk(3)+Xdn*Xk(4)* (Tp-
      T(I))
0032      Wk=Ewn*Xk(1)+Swn*Xk(2)+Wwn*Xk(3)+Xwn*Xk(4)
0033      Dwidw=U(7) *Awidw*Wk*(Tp-T(I))
0034      Grnd=U(8) *Width*XLgth*(Tp-Te)
0035      Tots=Fwall+Swall+Wwall+Xwall+Roof+Door+Dwidw+Grnd
0036      Vents=0.28* (Cn(I)+An(I))*V*(Tp-T(I))
0037      Toatal=Tots+Vents
      C      Calculation of Humidity
0038      Ventl=(Cn(I)+An(I)) *V*(Xp-X(I))* 715
0039      Hmdfy=(Cn(I)+An(I)) *V*(Xp-X(I))* 1.2
      C      Calculation of Machine-Load
0040      Totav=Total+Ventl
0041      A=6+2*I
0042      Write (6, 140) A, Total, Hmdfy, Totav
0043      140 Format (1H0, F10. 2, 5X, F10. 1, 5X, F10. 1, 5X, F10. 1)

```

0044 1000 Continue
 0045 Stop
 0046 End

FT 991 Data size=304, Procedure size= 1122
 FT 994 No diagnostics generated (Ftmain)
 FT 996 End of compilation (Ftmain)

표 6. 유입열에 대한 Computer Program

FACOM BOS/VS Fortran S -770127- Vol-L14

Options in Effect (Forts1)

Object, Nostack, Source, Nomap, Noisn, Ebcdic, Noautodbl, Nosequence, Noasterisk,
 Nodenseprint, Opt(O), Fmtarea(256), Flag(W), Debug(STD)

C Heat Gain Calculation
 C U; Heat Trasmission Coefficients.
 C T(I); Out Air Temp.
 C Tp; Indoor Air Temp.
 C X(I); Out Air Moisture Content.
 C Xp; Indoor Air Moisture Content.
 C Delt; Temperature Difference.
 C Igr; Solar Intensity.
 C Xuml; Watts of Lighting fixture
 C Xot; Motors
 C Off; Office Appliances
 C Peon; Number of People.
 C Cn; Air Change (Infiltration)
 C An; Air Change (Ventilation)
 C Wn; Number of Window
 C Db; Number of Door
 C Aks; Shading Coefficient.
 C Adoor; Area of One Door
 C Awidw; Area of One Window
 C Pcons; Sensible Heat of One People,
 C Pconl; Latent Heat of One People.
 C Width, Lenth, hight; Size of Room.
 C End; Enthalpy of out Air.
 C Hight; Hight of Wall
 C Width; Length of Wall Direction to N-S
 C Lenth; Length of Wall Direction to E-W
 C Vent; In filtration
 C Env; Enthalpy of Indoor Air.

```

0001      Implicit Real(L)
0002      Dimension U(8), T(8), X(8)
0003      Dimension Del T1(8), Del T2(8), Del T3(8), Del T4(8), Del T5(8)
0004      Dimension Eigr(8), Sigr(8), Wigr(8), Xigr(8)
0005      Dimension Peon(8), Xuml(8), Xot(8), O(8), Cfn(8), An(8)
0006      Read(5, 10) (U(N), N=1, 7)
0007      Read(5, 20) (Del T1(N), Del T2(N), Del T3(N), Del T4(N), Del T5(N),
0008      N=1, 5)
0008      Read(5, 30) (Eigr(N), Sigr(N), Wigr(N), Xigr(N), N=1, 5)
0009      Read(5, 60) (Peon(N), Xuml(N), Xot(N), Off(N), Cn(N), An(N), N=1, 5)
0010      Read(5, 40) (T(N), X(N), N=1, 5)
0011      Read(5, 10) Width, Lenth, Hight, Adoor, Awidw, Pcons, Pconl
0012      Read(5, 30) EWN, SWN, WWN, XWN
0013      Read(5, 30) EDN, SDN, WDN, XDN
0014      Read(5, 50) Aks, Tp, Xp
0015      10 Format (7F10, 5)
0016      20 Format (5F10, 5)
0017      30 Format (4F10, 5)
0018      40 Format (2F10, 5)
0019      50 Format (6F10, 5)
0020      60 Format (6F10, 5)
0021      ENP=0.24* Tp+Xp* (597.3+0.441* Tp)
0022      V=Width* Lenth* Hight
0023      Write (6, 110)
0024      110 Form at (/1H0, 35X, 27H*** Heat Gain Calculation*** //16X, 13H Sensible 1
13H Latent, 13H Total, 13X, 13H Vent, 13H 2Vent, 13H Vent /3X, 13H Time,
13H Heat, 13H 3 Heat, 13H Heat Gain, 13H Shf, 13H Sensible, 413H Latent
13H Total, 13H Total, 9H Usrt/ 516X, 13H (kcal/Hr), 13H (kcal/Hr), 13H
(kcal/Hr), 13X, 613H (kcal/Hr), 13H (kcal/Hr), 13H (kcal/Hr), 11H (kcal/Hr).
710H R/T/)

0025      Do 1000 I=1,5
0026      Ewall=U(1)* ((Width*Hight)-EWN*Awidw-EDN*Adoor)* (Del T1(I))
0027      Swall=U(2)* ((Lenth*Hight)-SWN*Awidw-SDN*Adoor)* Del T2(I)
0028      Wwall=U(3)* ((Width*Hight)-WWN*Awidw-WDN*Adoor)*Del T3(I)
0029      Xwall=U(4)* ((Lenth*Hight)-XWN*Awidw-XDN*Adoor)* Del T4(I)
0030      Roof=U(5)* Width*Lenth*Del T5(I)
0031      Door=U(6)* Adoor* (EDN+SDN+WDN+XDN)* (T(I)-Tp)
0032      Dwidw=U(7)* (EWN+SWN+WWN+XWN)*Awidw* (T(I)-Tp)
0033      Tot S1=Ewall+Swall+Wwall+Xwall+Roof+Door+Dwidw
0034      Ewidw=EWN*Awidw*AKS*Eigr(I)
0035      Swidw=SWN*Awidw*AKS*Sigr(I)
0036      Wwidw=WWN*Awidw*AKS*Wigr(I)
0037      Xwidw=NWN*Awidw*AKS*Xigr(I)

```

```

0038      Tot S2=Ewidw+Swidw+Wwidw+Xwidw
0039      Peos=Peon(I)*Pcons
0040      Xligt=Xuml(I)*1000
0041      Vents=0.28*Cn(I)*V* (T(I)-Tp)
0042      Elec=(Xot(I)+Off(I))* 860.
0043      Tot S3=Peos+Xligt+Vents+Elec
0044      Tots=Tot S1+Tot S2+Tot S3
0045      Peol=Peon(I)* Pconl
0046      Ventl=715. *Cn(I)* V*(X(I)-Xp)
0047      Totl=Peol+Ventl
0048      Total=Tots+Totl
0049      Env=0.24*T(I)+X(I)* (597.3+0.441* T(I))
0050      Vent=1.2*An(I)*V* (Env-ENP)
0051      Total=Vent+Total
0052      Shf=Tots/Total
0053      Rfton=Totav/3024.
0054      Tvent=Vents+Ventl
0055      A=6+2*1
0056      Write (6, 120) A, Tots, Totl, Total, Shf, Vents, Ventl, Tvent, Totav, Rfton
0057      120 Format(1H0, 6X, F5.2, 5X, 3F13.2, F9.4, 4X, 5F 13.2/)
0058      1000 Continue
0059      Stop
0060      End

```

FT 991 Data Size=552, Procedure size=1575

FT 994 No Diagnostics Generated (Ftmain)

FT 996 End of Compilation (Ftmain)